

TABELA WARTOŚCI PARAMETRÓW DLA WODY Z UJEĆ WODOCIĄGÓW MIEJSKICH W RADOMIU

Lp.	Nazwa ujęcia	magnez (mg/l)	wapń (mg/l)	sód (mg/l)	potas (mg/l)	fluorki (mg/l)	chlorki (mg/l)	siarczany (mg/l)	wodorowęglany (mg/l HC0 ₃ ⁻)	substancje rozpuszczone (mg/l)	data poboru
1	SUW Malczew	8,7	73	4,7	1,8	0,16	8,3	22	233	383	19.03.2024
2	SUW Sławno	16,0	100	6,7	2,0	0,17	16,0	23	343	362	19.03.2024
3	SUW 25-Czerwca	17,0	110	10,0	3,0	0,19	21,0	26	364	452	19.03.2024
4	SUW Obozisko	18,0	120	12,0	2,9	0,19	32,0	89	302	572	19.03.2024
5	SUW Potkanów	16,0	110	5,5	2,1	0,16	32,0	51	310	448	19.03.2024
6	SUW Lesiów	9,6	90	10,0	5,6	0,24	4,5	< 2	333	398	19.03.2024
7	SUW Białostocka	15,0	95	7,6	2,8	0,20	2,9	< 2	371	338	19.03.2024
8	SUW Firlej	15,0	105	8,2	1,9	0,14	24,0	66	289	360	19.03.2024
	Średnia wartość:	14,4	100	8,1	2,8	0,18	17,6	35	318	414	